



NOTES:

1. FOR EXPANSION JOINT INTERSECTIONS AND INTERSECTIONS BETWEEN EXPANSION JOINTS TO WALL OR EDGING, USE THREE LAYERS OF UNCURED ELASTOFORM FLASHING WITH EACH LAYER 3" (75 mm) LARGER THAN THE PREVIOUS LAYER IN ALL DIRECTIONS.
2. WHEN SURE-SEAL EXPANSION JOINT SUPPORT IS USED, WIDTH OF JOINT SHALL BE A MINIMUM OF 3/4" (19 mm) AND SHALL NOT EXCEED 3" (75 mm).
3. ADDITIONAL SECTION OF FLEECEBACK MEMBRANE (INSTALLED FLEECE SIDE UP) IS NOT REQUIRED WHEN MEMBRANE IS ADHERED WITH FAST ADHESIVE DIRECTLY TO AN APPROVED ROOF DECK OR EXISTING ROOFING MEMBRANE.

FB-3-A

DECK TO DECK EXPANSION JOINT

