



- NOTES:
1. ALL OUTSIDE AND INSIDE CORNERS REQUIRE TWO CORNER APPLICATIONS OF UNCURED ELASTOFORM FLASHING AS PER DETAIL FB-15.
  2. WHEN SURE-SEAL EXPANSION JOINT IS USED, WIDTH OF JOINT SHALL BE A MINIMUM OF 3/4" (19 mm) AND SHALL NOT EXCEED 2" (50 mm).
  3. PRESSURE-SENSITIVE 6" (150 mm) WIDE UNCURED ELASTOFORM FLASHING MAY ALSO BE CENTERED OVER FIELD SPLICE AT ANGLE CHANGE.
  4. ADDITIONAL SECTION OF FLEECEBACK MEMBRANE (INSTALLED FLEECE SIDE UP) IS NOT REQUIRED WHEN MEMBRANE IS ADHERED WITH FAST ADHESIVE DIRECTLY TO AN APPROVED ROOF DECK OR EXISTING ROOFING MEMBRANE.

# FB-3-B DECK TO WALL EXPANSION JOINT

