



NOTES:

1. FOR EXPANSION JOINT INTERSECTIONS AND INTERSECTIONS BETWEEN EXPANSION JOINTS TO WALL OR EDGING, USE 3 LAYERS OF UNCURED ELASTOFORM FLASHING WITH EACH LAYER 3" (75 mm) LARGER THAN PREVIOUS LAYER IN ALL DIRECTIONS.
2. WHEN SURE-SEAL EXPANSION JOINT SUPPORT IS USED, WIDTH OF JOINT SHALL BE A MINIMUM OF 3/4" (19 mm) AND SHALL NOT EXCEED 3" (75 mm).

30-YEAR WARRANTY

X3FB-3A

DECK TO DECK EXPANSION JOINT



© 2007 CARLISLE SYNTEC INCORPORATED